

2020 HVAC Project
Addendum 2

April 29, 2020

This addendum is to the project manual for the above referenced project at Meridian Technology Center.

To: All Holders of Contract Documents

- A. It is the intent of Meridian Technology Center for no permanent railing to be installed on the building. We are working with our safety trainers to install anchor points on the roof. These points will be accessible where required to meet OSHA and IMC requirements. Contractor will be responsible to provide all equipment which will connect the arrest/restraint anchorage.
- B. Per the City of Stillwater Building Inspector roofs that are sloped into roof drains do not have to have condensate lines running to the drain. There should be no condensate lines on this project.
- C. A request to submit AAON has been received and approved. Please note that this does not exclude any other manufacture that meets the quality of the basis of design.
- D. Use Tax: We have been asked if technology centers are subject to Use Tax. We are seeking clarification from the Oklahoma Tax Commission and will provide a response as Addendum 3 as soon as we clarify.

No additional RFI's were submitted as part of this project.